



Government of Karnataka
Public Works Department

Assistant Executive Engineer
Public Works Department, No.1 Subdivision
Ramanagara, Bangalore South District

Telephone: 080-27273787
email: aeeno.1pwd@gmail.com

BUILDING SAFETY CERTIFICATE

No. AEE/PWD/No.1 SD/RMGM/BUIL/2025-26/225

Date: 21-07-2025

It is Certified that the existing building Thyagaraju Central School at #30/1A, B.M.Road, Bidadi, Ramanagara 562109 is having block(s)/ Floor(s) as per the details below.

| Detail of Block(s) in Block school | Block (1) | Block (2) | Block (3) | Block (4) | Block (5) | Block (6) |
|------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|
| No. of Floor(s) in the Block | G +3 | - | - | - | - | - |

The building is owned/occupied by Thyagaraju Central School have complied with the Building Safety requirement in accordance with National Building code Rules, and verified by the officers concerned of Mr. Srinivasa of AEE, PWD No.1 Sub-Division, Ramanagara on 18-07-2025 (date of inspection) in the presence of Mrs. Vidhya Lakshmi N Principal, Thyagarju central School and that the building /premises is fit for running school with effect from 21-07-2025 for a period of 02 year in accordance with rule and subject to compliance of the specific conditions as appended.

1. Plastering and Painting to Existing Roof slab and walls.
2. Damp proofing works at All floors.
3. Crack sealing or grouting works at visible structural cracks at some location.
4. Crack sealing works at visible hairline cracks at some locations of wall and Column/Beam Junctions.
5. Damp proofing works to Toilet Block and repairs to avoid leakages in Sanitary lines.
6. Safety Measures for students and others.
7. Provide the Grill works to all around the building with open spaces, staircase area & Lift well area.
8. This certificate is not valid incase of any kind of natural disaster like cyclone & Earth Quake /Man-made disaster, any addition & Building
9. This certificate is valid for 2 years.

Regarding non-Structural elements(infrastructural facilities), a no-Objection Certificate should be obtained from a inspection personnel comprising of a Civil Engineer, Health Officer, Revenue Officer, psychologist, fire officer and officers of the local bodies and a "Fire Safety Certificate" should be obtained from the Chief Fire Officer.

Issued on 21-07-2025 Valid upto 20-07-2027 by

Assistant Executive Engineer
PWD, No.1 Subdivision

Ramanagara, Bangalore South District